

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING NO. 7165-0085:163 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: ADT, 4128 North Freeway Blvd, Sacramento, CA 95834  
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942\*

DESIGN: Model 472303 and 472361 Focus SSWF. Power-limited; local or central station service; automatic, manual, waterflow and sprnkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

|        |                    |
|--------|--------------------|
| 472303 | Control Unit       |
| 139778 | Relay              |
| 248028 | Relay Board (DPDT) |
| 245154 | Snaptrack          |
| 247650 | 4W/2W Interface    |
| 248035 | Loop Module        |
| 248026 | Relay Board (SPDT) |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**